

Jeff Watson

From: Brenda Larsen
Sent: Monday, November 21, 2011 7:58 AM
To: Jeff Watson
Subject: Charleton (BL-11-00025)

Follow Up Flag: Follow up
Flag Status: Flagged

Jeff Watson
Public Works Department
411 N. Ruby Street, Suite 2
Ellensburg, WA 98926

Re: Charleton (BL-11-00025)

Dear Mr. Watson:

After conducting a review of the above named project, I have the following comments:

- Ensure that boundary line adjustments do not infringe upon existing structures, to include propane tanks, etc.
- Creation of any additional roads or access must comply with the International Fire Code and KCC Title 12.
- All future development must comply with the International Fire Code.

Any questions or concerns regarding fire service features may be directed to the Kittitas County Fire Marshal's Office at 509-962-7000.

Sincerely,

Brenda Larsen
Kittitas County Fire Marshal
509-962-7000

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14