

## Jeff Watson

---

**From:** Brenda Larsen  
**Sent:** Wednesday, February 22, 2012 9:42 AM  
**To:** Jeff Watson  
**Subject:** BL-11-00029 Leonard

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

Jeff Watson  
Public Works Department  
411 N. Ruby Street, Suite 2  
Ellensburg, WA 98926

Re: Leonard (BL-11-00029)

Dear Mr. Watson:

After conducting a review of the above named project, I have the following comments:

- Ensure that boundary line adjustments do not infringe upon existing structures, to include propane tanks, etc.
- Any driveway greater than 150' in length shall have an all weather surface of 16' in width.
- All future development must comply with the International Fire Code.

Any questions or concerns regarding fire service features may be directed to the Kittitas County Fire Marshal's Office at 509-962-7000.

Sincerely,

*Brenda Larsen*  
*Kittitas County Fire Marshal*  
*509-962-7000*

---

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14