

## Jeff Watson

---

**From:** Holly Duncan  
**Sent:** Monday, February 13, 2012 11:33 AM  
**To:** Jeff Watson  
**Subject:** RE: BL-11-00029 Leonard

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

Jeff,

The applicant needs to be sure that proposed lines are not within 50 feet of existing wells and within 5 feet of drainfields.

Holly

---

**From:** Jeff Watson  
**Sent:** Tuesday, February 07, 2012 9:22 AM  
**To:** Christina Wollman; Brenda Larsen; Jan Ollivier; Holly Duncan  
**Subject:** BL-11-00029 Leonard

[BL-11-00029 Leonard](#)

Christina, Holly, and Brenda,

Could you please review this application for comment. Control Click on the hyperlink above (or go to the attachment tab in EDEN).

Thanks,

Jeffrey A. Watson  
Planner II  
[Kittitas County Public Works/Community Development Services](#)  
411 North Ruby  
Ellensburg WA 98926  
[jeff.watson@co.kittitas.wa.us](mailto:jeff.watson@co.kittitas.wa.us)  
509-933-8274

---

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14