

## Jeff Watson

---

**From:** Holly Duncan  
**Sent:** Monday, April 16, 2012 3:02 PM  
**To:** Jeff Watson  
**Subject:** RE: BL-12-00005 Howard

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

The proposed line must be at least 50 feet from the well and 5 feet from any portion of the drainfield. It is difficult to tell where the well is with the information given.

---

**From:** Jeff Watson  
**Sent:** Friday, April 13, 2012 3:21 PM  
**To:** Christina Wollman; Brenda Larsen; Jan Ollivier; Holly Duncan  
**Subject:** BL-12-00005 Howard

[BL-12-00005 Howard](#)

Christina, Holly, and Brenda,

Could you please review this application for comment. Control Click on the hyperlink above (or go to the attachment tab in EDEN).

Thanks,

Jeffrey A. Watson  
Planner II  
[Kittitas County Public Works/Community Development Services](#)  
411 North Ruby  
Ellensburg WA 98926  
[jeff.watson@co.kittitas.wa.us](mailto:jeff.watson@co.kittitas.wa.us)  
509-933-8274

---

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14