

Jeff Watson

From: Holly Duncan
Sent: Monday, June 04, 2012 11:17 AM
To: Jeff Watson
Subject: RE: BL-12-00008 Whitaker

Follow Up Flag: Follow up
Flag Status: Flagged

My concerns with this one are the locations of the wells and drainfields. All wells must be 50 feet from the proposed property lines and drainfields must be at least 5 feet from property lines.

From: Jeff Watson
Sent: Monday, June 04, 2012 9:34 AM
To: Christina Wollman; Brenda Larsen; Jan Ollivier; Holly Duncan
Subject: BL-12-00008 Whitaker

[BL-12-00008 Whitaker](#)

Christina, Holly, and Brenda,

Could you please review this application for comment. Control Click on the hyperlink above (or go to the attachment tab in EDEN).

Thanks,

Jeffrey A. Watson
Planner II
[Kittitas County Public Works/Community Development Services](#)
411 North Ruby
Ellensburg WA 98926
jeff.watson@co.kittitas.wa.us
509-933-8274

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14