## **Jeff Watson**

From: Brenda Larsen

**Sent:** Thursday, June 13, 2013 11:45 AM

**To:** Jeff Watson

**Subject:** RE: BL-13-00001 Seaton

Follow Up Flag: Follow up Flag Status: Flagged

Jeff Watson Public Works Department 411 N. Ruby Street, Suite 2 Ellensburg, WA 98926

Re: Seaton (BL-13-00001)

Dear Mr. Watson:

After conducting a review of the above named project, I have the following comments:

- Ensure that boundary line adjustments do not infringe upon existing structures, to include propane tanks, etc.
- Ensure adequate access for fire apparatus. Any driveways or access points created based off the new lot configurations shall comply with Kittitas County Code 20.02.030.
- All future development must comply with the International Fire Code.

Any questions or concerns regarding fire service features may be directed to the Kittitas County Fire Marshal's Office at 509-962-7000.

Sincerely,

Brenda Larsen Kittitas County Fire Marshal 509-962-7000

From: Jeff Watson

Sent: Wednesday, June 12, 2013 10:57 AM

To: Brenda Larsen

Subject: FW: BL-13-00001 Seaton

This is the one I mentioned

Jeffrey A. Watson Planner II Kittitas County Public Works/Community Development Services

411 North Ruby Ellensburg WA 98926 jeff.watson@co.kittitas.wa.us

509-933-8274

From: Jeff Watson

Sent: Friday, February 22, 2013 11:15 AM

To: Christina Wollman; Brenda Larsen; Jan Ollivier; Holly Duncan; Kelly Bacon

Subject: BL-13-00001 Seaton

## BL-13-00001 Seaton

Christina, Holly, and Brenda,

Could you please review this application for comment. Control Click on the hyperlink above (or go to the attachment tab in EDEN).

Thanks,

Jeffrey A. Watson
Planner II

<u>Kittitas County Public Works/Community Development Services</u>
411 North Ruby
Ellensburg WA 98926
jeff.watson@co.kittitas.wa.us
509-933-8274

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14