

## Jeff Watson

---

**From:** Holly Duncan  
**Sent:** Wednesday, May 22, 2013 12:20 PM  
**To:** Jeff Watson  
**Subject:** RE: BL-13-00006 Rinehart

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

Jeff,

As long as the proposed lot lines don't come within 50 feet of existing wells and 5 feet of existing drainfields there should be no problem with this application from the Environmental Health standpoint.

Holly

---

**From:** Jeff Watson  
**Sent:** Thursday, May 16, 2013 4:20 PM  
**To:** Christina Wollman; Brenda Larsen; Jan Ollivier; Holly Duncan  
**Subject:** BL-13-00006 Rinehart

[BL-13-00006 Rinehart](#)

Christina, Holly, and Brenda,

Could you please review this application for comment. Control Click on the hyperlink above (or go to the attachment tab in EDEN).

Thanks,

Jeffrey A. Watson  
Planner II  
[Kittitas County Public Works/Community Development Services](#)  
411 North Ruby  
Ellensburg WA 98926  
[jeff.watson@co.kittitas.wa.us](mailto:jeff.watson@co.kittitas.wa.us)  
509-933-8274

---

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14