

Jeff Watson

From: Joe Gilbert
Sent: Thursday, December 12, 2013 2:35 PM
To: Cruse & Associates (cruseandassoc@kvalley.com)
Cc: Jeff Watson
Subject: Smith BLA unofficial comments
Attachments: 1778_001.pdf

Hello again, I had John stop by and give me the run down, after identifying the well heads (attached) I ran into a small problem, it appears the well head for Johns main house is 50' from proposed prop line, but the shared well for the two other rentals is not. Not that it has to be because it is a shared well.... But it does need to remain on the parcel for which it serves the two other homes.... So that line will need to be changed and the well heads and distances will need to be on the next submittal, other than that it looks good.

It will just prevent having to deal with easements, agreements etc.... I hope this makes sense let me know if you have any questions, once this is resubmitted as described above I can move it along (send final approval comments to Jeff)... thanks.

JOE GILBERT, R.S.
LICENSED ON-SITE WASTEWATER
DESIGNER & INSPECTOR #5200273

KITTITAS COUNTY ENVIRONMENTAL HEALTH
507 N. NANUM SUITE 101
ELLENSBURG, WA 98926
509-933-8262

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14