

Kaycee Hathaway

From: Michael Flory
Sent: Monday, August 24, 2015 11:07 AM
To: Kaycee Hathaway; Brenda Larsen; Christina Wollman; Holly Myers
Subject: RE: BL-15-00010 Monjazez Notice of Application

Follow Up Flag: Follow up
Flag Status: Flagged

Hello Kaycee,

Thank you for the opportunity to comment on BL-15-00010 Monjazez.

If any area of development occurs within the hazardous slope area measuring more than 33% slope, specialized engineering will be required for soils, retaining walls and footings/foundations as stipulated in IRC 403.1.7.

Thank you again,

Michael Flory
Certified Building Official

Kittitas County Community Development Services
411 N Ruby Street Suite 2
Ellensburg, WA 98926
mike.flory@co.kittitas.wa.us
P: 509.933.8222
F: 509.962.7682



"Building Partnerships-Building Communities"

From: Kaycee Hathaway
Sent: Monday, August 24, 2015 9:21 AM
To: Brenda Larsen; Christina Wollman; Holly Myers; Michael Flory
Subject: BL-15-00010 Monjazez Notice of Application

Please review the below application. All comments are due by **September 8, 2015**.

[BL-15-00010 Monjazez](#)

Kaycee K Hathaway
Kittitas County
Community Development Services/ Planner I
Phone: (509) 962-7079
Email: kaycee.hathaway@co.kittitas.wa.us

message id: 38eb45916c6dcbdac24bb8719d004a14