



KITTITAS COUNTY FIRE MARSHAL'S OFFICE

411 N. Ruby St., Suite 2, Ellensburg, WA 98926

Office (509) 962-7657 Fax (509) 962-7682

December 10, 2015

Jeff Watson
Staff Planner
Community Development Services
411 N. Ruby Street, Suite 2
Ellensburg, WA 98926

Re: Anderson (BL-15-00016)

Dear Mr. Watson:

Upon review of the above mentioned land use action, I have the following comments/requirements;

- Ensure that boundary line adjustments do not infringe upon existing structures, to include propane tanks, etc.
- Ensure adequate access for fire apparatus. Any driveways or access points created based off the new lot configurations shall comply with Kittitas County Code 20.02.030.
- All future development must comply with the International Fire Code.

Any questions or concerns regarding fire service features may be directed to the Kittitas County Fire Marshal's Office at (509) 962-7000.

Sincerely,

Brenda Larsen
Fire Marshal