

From: Dusty Pilkington
To: [Holly Duncan](#)
Subject: RE: Bailey BL
Date: Monday, August 01, 2016 9:04:00 AM

No worries. Thanks.

Dusty Pilkington
Planner I
Kittitas County Community Development Services
411 N Ruby St # 4, Ellensburg, WA 98926
(509) -962-7079
dusty.pilkington@co.kittitas.wa.us

From: Holly Duncan
Sent: Monday, August 01, 2016 9:03 AM
To: Dusty Pilkington
Subject: RE: Bailey BL

Yes, sorry but I left on vacation last Monday. Otherwise, I would have gotten back to you sooner.

From: Dusty Pilkington
Sent: Monday, July 25, 2016 4:31 PM
To: Holly Duncan
Subject: RE: Bailey BL

Thanks Holly. Can I consider this your comment as I continue to process the application?

Dusty Pilkington
Planner I
Kittitas County Community Development Services
411 N Ruby St # 4, Ellensburg, WA 98926
(509) -962-7079
dusty.pilkington@co.kittitas.wa.us

From: Holly Duncan
Sent: Monday, July 25, 2016 12:18 PM
To: Dusty Pilkington
Subject: RE: Bailey BL

As long as the well is at least 50 feet from property lines, it's fine. It's difficult to tell if the scale is accurate on this. There also should be a shared well use agreement in place since the mylar says shared well.

From: Dusty Pilkington
Sent: Friday, July 22, 2016 1:13 PM
To: Holly Duncan
Subject: RE: Bailey BL

Follow the hyperlink below. It should be the fifth item, marked "Revised Site Plan". Holly Myers already looked at it and it was still incomplete for her needs, it may be incomplete for yours as well. I have already messaged the applicant to get a new site plan.

Thank you!

Dusty

[BL-16-00009-Bailey](#)

From: Holly Duncan
Sent: Friday, July 22, 2016 12:18 PM
To: Dusty Pilkington
Subject: Bailey BL

Can you please forward the updated plans submitted on this project to me for review?

Holly Duncan
Environmental Health Specialist II
Kittitas County Public Health Department
507 N. Nanum St., Suite 102
Ellensburg, WA. 98926
(509)962-7580
Holly.duncan@co.kittitas.wa.us

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14