

From: [Holly Myers](#)
To: [Dusty Pilkington](#)
Subject: FW: BL-16-00009 Bailey
Date: Thursday, July 21, 2016 5:57:22 PM

FYI on the Bailey project.

Holly R Myers

Environmental Health Supervisor

Kittitas County Public Health Department

P-(509)962-7005

Holly.myers@co.kittitas.wa.us

CELEBRATE EVERY DAY!

From: Fiske Firebaugh
Sent: Wednesday, July 13, 2016 3:34 PM
To: Holly Myers
Subject: RE: BL-16-00009 Bailey

Hi Holly,

I did not see any issues with this boundary line adjustment. Just for your information the following parcels are completely or partially in a floodway. Septic systems cannot be placed in floodways. Septic systems can only be installed in floodways if it is a repair.

657435- partially located in floodway

667435- partially located in floodway

837335- completely in floodway

847335- partially located in floodway

Fiske

From: Holly Myers
Sent: Wednesday, July 06, 2016 6:56 PM
To: Holly Duncan; Fiske Firebaugh
Subject: FW: BL-16-00009 Bailey

Please provide your comments back by Friday July 15.

Holly R Myers

Environmental Health Supervisor

Kittitas County Public Health Department

P-(509)962-7005

Holly.myers@co.kittitas.wa.us

CELEBRATE EVERY DAY!

From: Dusty Pilkington
Sent: Wednesday, July 06, 2016 9:30 AM
To: Kelly Bacon; Holly Duncan; Holly Myers; Josh Hink; Lucas Huck
Subject: BL-16-00009 Bailey

[BL-16-00009 Bailey](#)

Kelly, Hollys, and Josh

Could you please review this application and submit comments for the decision. Control Click on the hyperlink above (or go to the attachment tab in EDEN). Comment period for this application ends on 7/20/2016.

Thanks,

Dusty Pilkington
Planner I
Kittitas County Community Development Services
411 N Ruby St # 4, Ellensburg, WA 98926
(509) -962-7059
dusty.pilkington@co.kittitas.wa.us

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14