

Dusty Pilkington

From: Rich Elliott <elliotttr@kvfr.org>
Sent: Wednesday, February 01, 2017 10:35 AM
To: Dusty Pilkington
Cc: Joe Seemiller
Subject: RE: BL-17-00002 Williams

When building permit is issued:

1. Insure access and turnaround for property complies with Appendix D – current IFC.
2. Insure addressing for structure is clearly visible from both direction of travel on county road.
3. WUI assessment requirement compliance.

From: Dusty Pilkington [<mailto:dusty.pilkington@co.kittitas.wa.us>]
Sent: Wednesday, February 01, 2017 10:23 AM
To: Kelly Bacon; Holly Duncan; Holly Myers; Josh Hink; Lucas Huck; Keli Bender; Rich Elliott; Dr. Paul Farris, Ellensburg School District; fwalker@eburg.wednet.edu
Subject: BL-17-00002 Williams

Kelly, Hollys, Josh, and other interested parties,

Could you please review this application and submit comments for the decision. Control Click on the hyperlink above (or go to the attachment tab in EDEN). Comment period for this application ends on **02/15/2017**

[BL-17-00002 Williams \(County Departments\)](#)
[BL-17-00002 Williams \(Outside County Network\)](#)

Dusty Pilkington
Planner I
Kittitas County Community Development Services
411 N Ruby St # 4, Ellensburg, WA 98926
(509) -962-7079
dusty.pilkington@co.kittitas.wa.us

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14