

Chelsea Benner

From: Holly Erdman
Sent: Tuesday, September 17, 2019 4:55 PM
To: Chelsea Benner
Cc: Jesse Cox
Subject: RE: Notice of Application BL-19-00018 Carney

Follow Up Flag: Follow up
Flag Status: Flagged

Chelsea,

Thank you for the opportunity to comment on this project.

The proposed well that will be located on Parcel "A" to serve the existing residence will be required to meet all setbacks; 50 feet from all property lines, 50 feet from the existing septic tank and 100 feet from the existing drainfield and future replacement drainfield.

Thank you,

Holly Erdman, BS, Environmental Health Specialist II

P: 509.962.7580 | F: 509.962.7581 | E: holly.erdman@co.kittitas.wa.us

Kittitas County Public Health Department
507 N Nanum St Suite 102, Ellensburg WA 98926

www.co.kittitas.wa.us/health

Please tell us how we're doing: [KCPHD Customer Survey](#)



From: Chelsea Benner
Sent: Monday, September 16, 2019 8:51 AM
To: Holly Erdman; Jesse Cox; Pat Nicholson; Toni Berkshire; Candie Leader; Gail Weyand
Subject: Notice of Application BL-19-00018 Carney

Good Morning,

Please review the following Boundary Line Adjustment application submitted by Lloyd Carney (BL-19-00018). Any comments need to be submitted by 5pm on October 1st. Please let me know if you have any questions.

[BL-19-00018 Internal](#)

[BL-19-00018 External](#)

Thank you,

Chelsea Benner

Planner I

Kittitas County Community Development Services

411 N Ruby Street, Suite 2 Ellensburg, WA 98926

(p) 509-962-7506 (f) 509-962-7682

chelsea.benner@co.kittitas.wa.us

Notice: Email sent to Kittitas County may be subject to public disclosure as required by law.
message id: 38eb45916c6dcbdac24bb8719d004a14