



KITITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Planning Review Team
DATE: March 3, 2020
SUBJECT: County Survey Review of BL-19-00023 Brunner

Suggestions (not required):

1. Wilson Creek Road should include ownership and paving details (county-paved).
2. The south line of Parcel 2 does not match closure report (17" vs 12"). Even with the differences, the values shown still meet closure requirements.

Public Works has no other comments on this application.