

From: [Pat Nicholson](#)
To: [Rachael Stevie \(CD\)](#)
Subject: RE: BL-20-00008 Ogg - Notice of Application
Date: Thursday, March 12, 2020 8:22:22 AM
Attachments: [image001.png](#)

The access will need to meet current IFC and PW standards for 20 foot width, 75,000 lb capacity, and grade with an approved turn around.

From: Rachael Stevie (CD) <rachael.stevie.cd@co.kittitas.wa.us>
Sent: Wednesday, March 11, 2020 10:30 AM
To: Pat Nicholson <pat.nicholson@co.kittitas.wa.us>; Candie Leader <candie.leader@co.kittitas.wa.us>; Holly Erdman <Holly.erdman@co.kittitas.wa.us>; Jesse Cox <jesse.cox@co.kittitas.wa.us>
Cc: Lindsey Ozbolt <lindsey.ozbolt@co.kittitas.wa.us>
Subject: BL-20-00008 Ogg - Notice of Application


Good morning,

Please review the following Boundary Line Adjustment application submitted David and Kathleen Ogg (BL-20-00008). Any comments need to be submitted by 5pm on March 26, 2020. Please let me know if there are any questions.

Internal Link: [BL-20-00008 Ogg](#)

External access: The submitted application and related filed documents may be examined by external agencies and the public on the CDS website <https://www.co.kittitas.wa.us/cds/land-use/default.aspx>, under "Boundary Line Adjustments" then navigate to permit number "BL-20-00008 Ogg".

Thank you,



Planner I
Kittitas County
Community Development Services
411 N. Ruby Street; Suite 2
Ellensburg, WA 98926
509-962-7637
rachael.stevie.cd@co.kittitas.wa.us