



KITITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: June 1, 2022
SUBJECT: BL-22-00014 Maultsby

The Public Works Department has reviewed the Request for Boundary Line Adjustment Application. The applicant needs to be aware of the following:

- a. An approved access permit shall be required from the Kittitas County Department of Public Works prior to creating any new driveway access or altering an existing access.
- b. Maintenance of driveway approaches shall be the responsibility of the owner whose property they serve. The County will not maintain accesses.
- c. Any further subdivision or lots to be served by proposed access may result in further access requirements. See Kittitas County Road Standards.
- d. Except as exempted in Section KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080).

In addition to the above-mentioned conditions, all applicable Kittitas County Road Standards apply to this proposal. Access is not guaranteed to any existing or created parcel on this application.

SURVEY:

1. Correct multiple instances of text being obscured by crossing linework. (RCW 58.09.050(4)), (WAC:332-130-050(1)(d)(i)) and (WAC:332-130-050(1)(d)(ii))
2. Show offset distance from Westernmost boundary to fence encroachments.
Show offset distance from Westernmost boundary to fence encroachments.
3. Roadways must show name, width, underlying ownership, easement or right of way and surface type.
4. Existing easements must show type of easement (access/ utility/ irrigation) as well as the identified recording number and width.
5. Legend may need to be updated with line type for fence.