

Kaycee Hathaway

From: Mau, Russell E (DOH) <Russell.Mau@DOH.WA.GOV>
Sent: Wednesday, March 18, 2015 9:53 AM
To: Kaycee Hathaway
Cc: Holly Myers; Holly Duncan; 'binxbuds@gmail.com'
Subject: RE: CU-14-00005 McDonald Employee Water Plan

Ms. Hathaway:

DOH agrees with their approach.

Per "signage", DOH would be looking for a sign or signs (either a very "large" sign somewhere near the entry to the facility, or smaller, yet obvious, signs at each faucet/spigot/hydrant) that state: "DO NOT DRINK THE WATER – NONPOTABLE". Also, depending on owners, contractors and potential employee ethnicities and so forth, bilingual signs may be reasonable.

At this point, as long as they do not have an approved water system, providing these signs is the only involvement DOH has with this business.

In the future, if they do seek/need an approved water system, they need to be aware that pulling together source and water system approval applications, from start to approval, can take several months and parts require a Professional Engineer, licensed in the State of Washington.

Thanks,

Russell E. Mau, PhD, PE

Regional Engineer
Department of Health, Office of Drinking Water
16201 East Indiana Avenue, Suite 1500, Spokane Valley, WA 99216

Desk: 509-329-2116

Fax: 509-329-2104

Russell.Mau@DOH.WA.GOV

Public Health - Always Working for a Safer and Healthier Washington

Visit our web site at www.doh.wa.gov/ehp/dw

From: Kaycee Hathaway [<mailto:kaycee.hathaway@co.kittitas.wa.us>]
Sent: Wednesday, March 18, 2015 9:41 AM
To: Mau, Russell E (DOH)
Cc: Holly Myers; Holly Duncan; 'binxbuds@gmail.com'
Subject: CU-14-00005 McDonald Employee Water Plan

Dear Dr. Mau,

Based upon your comment email form 12-11-2014 the applicant has submitted clarifying information. Attached is a copy of Mr. McDonalds water plan for his employees. If you could please specify what else DOH needs to satisfy and health standards or codes please comment further.

Thank you,

Kaycee K Hathaway
Kittitas County
Community Development Services/ Planner I
Phone: (509) 962-7079
Email: kaycee.hathaway@co.kittitas.wa.us

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14