



# KITTITAS COUNTY DEPARTMENT OF PUBLIC WORKS

411 N. RUBY STREET, SUITE 1 ELLENSBURG, WA 98926

(509) 962-7523

MARY GONZALAZ  
1006 EMERSON RD  
ELLENSBURG WA 98926

# RECEIVED

FEB 11 2015

KITTITAS COUNTY  
CDS

Permit No.: **EX-15-00005**

Application Date: January 20, 2015

Issue Date: February 09, 2015

Application Status: final

Expiration Date: **July 19, 2015**

February 09, 2015

Dear MARY GONZALAZ;

Your access/address onto Emerson Rd

has been conditionally approved by Kittitas County with the following conditions:

## APPLICATION INFORMATION

Application for:  Address Permit  Access Permit

Assessor Map No.: 17-19-27053-0002

Access Requested for: \_\_\_\_\_ Desired Width of Driveway: \_\_\_\_\_ Feet

Nearest Intersection or Address: \_\_\_\_\_

## NEW ADDRESS

Your New Address is: Emerson Rd

City: \_\_\_\_\_ Zip: \_\_\_\_\_

## ACCESS REQUIREMENTS

### ALL REQUIREMENTS OF PERMIT TO BE COMPLETED PRIOR TO ISSUANCE OF:

BUILDING PERMIT  OCCUPANCY PERMIT

**PAVED APRON REQUIRED - WSDOT DESIGN STANDARDS**

**PRIVATE ROAD CERTIFICATION REQUIRED**

**CULVERT REQUIRED**

Minimum Culvert Diameter: \_\_\_\_\_ Inches

Minimum Beveled End Length: \_\_\_\_\_ Feet

Total Culvert Length: \_\_\_\_\_ Feet

### CULVERT LENGTH CALCULATION

Length = W + 8H + 2 (All Measurements in Feet)

W = Width of driveway

8 = (Constant) Angle of side slopes (2x4:1)

H = Height of culvert + depth of fill above culvert

2 = (Constant) One-foot pipe extension beyond fill ends

- Pipe to be bedded on a minimum of 4" of 5/8 gravel or equivalent, with a minimum cover of \_\_\_\_\_ inches.
- Culverts shall be constructed of new galvanized steel or new plastic HDPE pipe.
- Maintain a 4:1 slope from the driveway surface to the top of culvert.
- Bevels on culvert to be cut at a 4:1 slope.

**INSPECTION OF COMPLETED ACCESS REQUIRED CALL 509-962-7523 TO SCHEDULE YOUR INSPECTION**

Other Requirements/Comments:

Road improvements are sufficient at this time. No requirements at this time.

# EXEMPT

Reviewed By: KELLY BACON

Date: 02/09/2015

Approved By: \_\_\_\_\_

Date: \_\_\_\_\_