

## Lindsey Ozbolt

---

**From:** Benson, Richard (DOH) <Richard.Benson@DOH.WA.GOV>  
**Sent:** Tuesday, February 09, 2016 2:29 PM  
**To:** Lindsey Ozbolt  
**Cc:** El-Aarag, Mamdouh (DOH); Mau, Russell E (DOH)  
**Subject:** DOH comments: Yakima River Campground CU-15-00002 Notice of Application

Ms. Ozbolt:

This proposal is to operate a new campground/RV Park and utilize a number of existing septic systems on the site which “may need to be updated”. We don’t have information about the existing septic systems but if any of them have design flows  $\geq 3500$  GPD (possible for 172 campsites and 18 cabins) they are “Large Onsite Sewage Systems” which fall within our regulatory jurisdiction and must meet requirements in our rule (operating permit and approval for modifications required).

*Richard M. Benson, P.E.*  
*Dept. of Health / OEHHS / Large Onsite Program*  
*16201 E Indiana AVE - STE # 1500*  
*Spokane Valley WA 99216*  
*(509) 329-2147; Fax (509) 329-2142*  
[\*richard.benson@doh.wa.gov\*](mailto:richard.benson@doh.wa.gov)  
[\*LQSS Program Website\*](#)

*Public Health - Always Working for a Safer and Healthier Washington*