



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY
1250 W Alder St • Union Gap, WA 98903-0009 • (509) 575-2490

November 9, 2015

Kaycee Hathaway
Kittitas County Community Development
411 N. Ruby Street, Suite 2
Ellensburg, WA 98926

Re: CU-15-00004

Dear Ms. Hathaway:

Thank you for the opportunity to comment during the optional determination of nonsignificance process for the Zayo Vantage Hwy Telecommunication Shelter on 81.6 acres, proposed by Les Nash. We have reviewed the documents and have the following comments.

AIR QUALITY

Stationary emergency internal combustion engines (emergency generators) with an aggregate brake horsepower greater than 500 brake horsepower require a preconstruction air quality permit. For information regarding air permit applicability and/or process, please contact Lynnette Haller at (509)457-7126 or lynnette.haller@ecy.wa.gov .

Sincerely,

Gwen Clear
Environmental Review Coordinator
Central Regional Office
(509) 575-2012
crosepacoordinator@ecy.wa.gov

4882

