



STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY  
1250 W Alder St • Union Gap, WA 98903-0009 • (509) 575-2490



November 9, 2015

Kaycee Hathaway  
Kittitas County Community Development  
411 N. Ruby Street, Suite 2  
Ellensburg, WA 98926

Re: CU-15-00005

Dear Ms. Hathaway:

Thank you for the opportunity to comment during the optional determination of nonsignificance process for the telecommunications facility on 90 acres, proposed by Ski Lifts Inc. We have reviewed the documents and have the following comments.

#### AIR QUALITY

Stationary emergency internal combustion engines (emergency generators) with an aggregate brake horsepower greater than 500 brake horsepower require a preconstruction air quality permit. For information regarding air permit applicability and/or process, please contact Lynnette Haller at (509)457-7126 or [lynnette.haller@ecy.wa.gov](mailto:lynnette.haller@ecy.wa.gov).

Sincerely,

Gwen Clear  
Environmental Review Coordinator  
Central Regional Office  
(509) 575-2012  
[crosepaordinator@ecy.wa.gov](mailto:crosepaordinator@ecy.wa.gov)

4883

