

From: [Mau, Russell E \(DOH\)](#)
To: [Dusty Pilkington](#)
Cc: [Serr, Ben A \(DOH\)](#); [Holly Duncan](#); [Holly Myers](#)
Subject: RE: CU-15-00007 NW Champanzee PH Comments
Date: Tuesday, July 26, 2016 3:32:18 PM

Mr. Pilkington:

My previous comment is still applicable (see attached email); in addition, with the given population numbers meeting a criterion for being a Group A water system, DOH agrees that adding onto this water system would result in the need for a re-classification to a Group A water system. This reclassification requires a Group A application submitted to DOH for review and approval.

So, DOH requires the following:

- A Capacity Analysis, required to be completed by a professional engineer licensed in the State of Washington.
- A Group A water system application.

Thanks,

Russell E. Mau, PhD, PE
Regional Engineer
Department of Health, Office of Drinking Water
16201 East Indiana Avenue, Suite 1500, Spokane Valley, WA 99216
Desk: 509-329-2116
Fax: 509-329-2104
Russell.Mau@DOH.WA.GOV

Public Health - Always Working for a Safer and Healthier Washington

Visit our web site at www.doh.wa.gov/ehp/dw

From: Dusty Pilkington [mailto:dusty.pilkington@co.kittitas.wa.us]
Sent: Tuesday, July 26, 2016 3:18 PM
To: Mau, Russell E (DOH)
Subject: FW: CU-15-00007 NW Champanzee PH Comments

Mr. Mau,

Below is an email from Kittitas County Public Health. If the system needs to be reclassified, I believe there may be reason for you to change or update your comments. Either way, I wanted to give you a heads up as I write up my report and threshold determination.

Dusty Pilkington
Planner I
Kittitas County Community Development Services
411 N Ruby St # 4, Ellensburg, WA 98926
(509) -962-7079
dusty.pilkington@co.kittitas.wa.us

From: Holly Myers
Sent: Tuesday, July 26, 2016 3:03 PM
To: Dusty Pilkington
Subject: CU-15-00007 NW Champanzee PH Comments

The water system (Hart Ranch ID#: AA391M) needs an updated nitrate test done to be up to date on testing.

The numbers of people they indicate will be using the water system are higher than the numbers that are shown on the current WFI form. An update to the current WFI form will need to be done showing the accurate numbers of regular non-residential users. The numbers in the project narrative indicate the system may need to be re-classified to a Group A system in which case they will need to work with DOH on that approval and upgrade prior to the addition of users.

These conditions should be mitigated for.

Holly R Myers

Environmental Health Supervisor

Kittitas County Public Health Department

P-(509)962-7005

Holly.myers@co.kittitas.wa.us

CELEBRATE EVERY DAY!

From: Dusty Pilkington
Sent: Tuesday, July 26, 2016 2:56 PM
To: 'separegister@ecy.wa.gov'; sepaunit@ecy.wa.gov; gcle461@ecy.wa.gov; 'craj461@ecy.wa.gov'; 'Brent.Renfrow@dfw.wa.gov'; Scott.Downes@dfw.wa.gov; Nelson, Jennifer L (DFW); Holly Duncan; Holly Myers
Subject: Possibly Missing Comments on this one.

Greetings. I am finishing up SEPA review for this project. I do not have any comments on file from Ecology, Fish and Wildlife, or Kittitas Public Health. I would like to give one last chance for comment before proceeding. Thanks all!

[CU-15-00007 Northwest Chimpanzee Sanctuary \(Hyperlink for County Network\)](#)

[CU-15-00007 Northwest Chimpanzee Sanctuary \(Hyperlink for Kittitas County Website\)](#)

Dusty Pilkington
Planner I
Kittitas County Community Development Services
411 N Ruby St # 4, Ellensburg, WA 98926

(509) -962-7079

dusty.pilkington@co.kittitas.wa.us

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14