



KITTITAS COUNTY FIRE MARSHAL'S OFFICE

411 N. Ruby St., Suite 2, Ellensburg, WA 98926

Office (509) 962-7000 Fax (509) 962-7682

May 13, 2019

Re: Brightside Vintage Farm Fire Flow

To Whom it May Concern,

Brightside Vintage Farm has recently made application with the county to propose a multi-phase project on the property.

Phase I includes the intermittent setup of a temporary membrane tent to be used as an assembly occupancy to host various private events.

No additional fire-flow requirements are required for this phase of the project. Subsequent phases mentioned in a pre-application conference indicate that one or more structures will be built and will have fire-flow and potentially sprinkler requirements when those phases are proposed. We are only addressing Phase I at this time.

There are draft capabilities on the property for fire department use and the local fire agency would respond water tender apparatus for water needs in the event of a fire.

Respectfully,

Patrick Nicholson, Fire Marshal

P r e v e n t i o n • E d u c a t i o n • I n v e s t i g a t i o n • E n f o r c e m e n t
D e c e m b e r 1 7 , 2 0 1 8

FIRE MARSHAL PATRICK NICHOLSON, IFSAC CFI, NAFI CFEL, CVFI