



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: Community Development Services
FROM: Gail Weyand, Engineering Technician I
DATE: September 16, 2020
SUBJECT: PM-20-00008 I-90 Storage

Public Works Pre-Application Comments

- Any change in access or addressing will require an access/address permit from Public Works.
- Grading over 100 cubic yards of material requires a grading permit. Any grading over 500 cubic yards of material will require engineered grading and storm water plans. See Kittitas County Code chapter 14.05.
- Engineered stormwater plans are required if the project generates an impervious surface exceeding 5000 square feet. The stormwater system will comply with the Stormwater Management Manual for Eastern Washington (SWMMEW).

Please contact Kittitas County Public Works (509) 962-7523 with any questions.