



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: Community Development Services
FROM: Gail Weyand, Engineering Technician I
DATE: June 2, 2021
SUBJECT: PM-21-00010 Kittitas PUD Bettas Rd Substation Expansion

Public Works Pre-Application Comments

- Engineered stormwater plans are required if the project generates an impervious surface exceeding 5000 square feet. The stormwater system will comply with the Stormwater Management Manual for Eastern Washington (SWMMEW).
- Applicant is using an existing access, so no access permit is required.

Please contact Kittitas County Public Works (509) 962-7523 with any questions.