



KITITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: June 10, 2022
SUBJECT: CU-22-00001 Apostolic Faith United

The Public Works Department has reviewed the Request for Conditional Use.

The applicant needs to address the following prior to Public Works' approval:

- a. A transportation impact analysis (TIA) shall be required for all development that will generate more than nine (9) peak hour vehicle trips. Please provide estimated traffic generation for peak hours to determine if a TIA will be required. (KCC 12.10.040(c))

The applicant needs to be aware of the following:

- a. An approved access permit shall be required from the Kittitas County Department of Public Works prior to creating any new driveway access or altering an existing access.
- b. Maintenance of driveway approaches shall be the responsibility of the owner whose property they serve. The County will not maintain accesses.
- c. Except as exempted in Section KCC 14.05.060, no grading or filling upon a site involving more than one hundred (100) cubic yards shall be performed without a grading permit from the County Engineer or Public Works designee (KCC 14.05.050). An application for grading in excess of five hundred (500) cubic yards shall be accompanied by an engineered grading plan (KCC 14.05.080).
- d. In addition to the above-mentioned conditions, all applicable Kittitas County Road Standards apply to this proposal. Access is not guaranteed to any existing or created parcel on this application.