

Alex Cordas

---

**From:** Holly Erdman <Holly.erdman@co.kittitas.wa.us>  
**Sent:** Friday, June 29, 2018 9:47 AM  
**To:** Mike Flory; Steph Mifflin; Rachel Kane; Kathy Boots  
**Cc:** Alex Cordas  
**Subject:** Swauk Valley Ranch permit

RECEIVED  
JUL 24 2018

Mike,

Please accept the Swauk Valley Ranch, LLC, permit application and allow their plans to begin the review process. They have satisfied the requirements needed for the water system but are unable to obtain their water certificate until the parcel number has been assigned. By the time their plans have been through your review process they should have a parcel number assigned as well as a water certificate and thus will be able to obtain their water adequacy approval.

I ask at this time that you not release their permit until water adequacy has been approved through our office.

Please call me if you have any questions. Thank you for your time and cooperation in this matter.

**HOLLY ERDMAN**  
**ENVIRONMENTAL HEALTH SPECIALIST**  
**KITTITAS COUNTY PUBLIC HEALTH DEPARTMENT**  
**507 N. NANUM STREET, SUITE 102**  
**ELLENSBURG, WA. 98926**

**509-962-7580**

---

Notice: Email sent to Kittitas County may be subject to public disclosure as required by law.  
message id: 38eb45916c6dcbdac24bb8719d004a14



## Midstate Co-Op

P.O. Box 480  
 Ellensburg, Wa 98926  
 Phone (509) 925-3171  
 Fax (509) 962-3380

### Pump Test Data Sheet

Name: Eric Morris  
 Address: 18511 Hwy 10  
 Ellensburg, Wa 98926  
 Use: Domestic

Date: 7/9/10

Measuring Point: Top Of Casing 2'  
 Well Depth: ? Casing Installed: 6" Steel  
 Discharge Rate: 48 gpm

Conducted By: Jerry  
 Pump Used: 5HP 45 Gpm

Time	PSI	Pumping Level	Draw	GPM	Comments
10:35 AM	40	24	0	60	Clean
10:40 AM	55	51	28	55	Clean
11:00 AM	60	61	10	58	Clean
11:15 AM	60	62	1	10	Clean
11:30 AM	65	65	3	48	Clean
11:45 AM	65	65	0	48	Clean
12:00 PM	65	65	0	48	Clean
12:30 PM	65	65	0	48	Clean
1:00 PM	65	65	0	48	Clean
1:30 PM	65	65	0	48	Clean
2:00 PM	65	65	0	48	Clean
2:30 PM	65	65	0	48	Clean
3:00 PM	65	65	0	48	Clean
3:30 PM	65	65	0	48	Clean

Recovery: From 65' to 24' in 10 min