

Subdivision Comments

To: Chelsea Benner, Planning Official

From: Jesse Cox, Environmental Health Supervisor

Date: Sept 30, 2019

RE: LPF-19-00008

Thank you for the opportunity to comment on the above mentioned project regarding water and septic requirements to comply with Kittitas County Public Health Department's Environmental Health requirements.

Findings

On Site Sewage

- The LPF-19-00008 Suncadia phase 3 Divisions 15 & 16 project is served by an off-site gravity sewer to the waste water treatment plant.

Water

- The LPF-19-00008 is proposing 105 additional residential lots on the Suncadia water system. They currently are approved for 1501 connections, and have 590 active connections, so they are able to serve the additional 105 lots in this proposal.

A Additional Information Required

No information is required for further review prior to any determinations leading to recommendation for approval.