



**KITITIAS COUNTY**  
**DEPARTMENT OF PUBLIC WORKS**

Mark R. Cook, PE Director

June 19, 2018

Ms. Laura Bartenhagen, PE  
ESM Consulting Engineers LLC  
33400 8<sup>th</sup> Avenue South, Suite 205  
Federal Way, WA 98003

**RECEIVED**  
**JUN 20 2018**

Kittitas Co. CDS

RE: Phase 3 Division 14  
Engineering Plan Submittal

Dear Ms. Bartenhagen:

We have completed a review of materials submitted to Community Development Services (May 04, 2018) and our comments appear below for your use.

1. Please provide a road design profile for Tired Creek Lane and the access roadway east of the cul de sac.
2. Please provide roadway geometric data (horizontal alignment).
3. Please provide supporting stormwater design calculations. Please discuss the capacity of the facility in the golf course and the anticipated capacity utilized by this proposal.
4. It appears that the sanitary sewer (8 inch) connects westerly to Phase 3 Divisions 6 to 9. Please verify that all sewage flows are gravity flows from Phase 3 Division 14.

Please let me know if you have any questions regarding our review.

Sincerely,

Mark R. Cook, PE  
Director/Acting County Engineer

C: Ms. Lindsey Ozbolt, Planning Official  
Ms. Taylor Gustafson, Planner III