



KITTITAS COUNTY
DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: Community Development Services
FROM: Taylor Gustafson, Transportation/Environmental Planner TG
DATE: June 28, 2018
SUBJECT: County Review of LP-18-00002 (Suncadia)

The following shall be conditions of preliminary approval:

RECEIVED
JUN 28 2018

Survey:

Kittitas Co. CDS

Required Changes:

1. The Prelim Plat must include a stamp from a licensed land surveyor on all sheets.
2. All pages must include page number and total number of pages.
3. The intended ownership limits of Lot 10 / AC-1 is unclear. Is AC-1 intended to be 20' wide or 30' wide?
4. Tired Creek lane should include width, ownership and surfacing (EX: TIRED CREEK LANE – 30' wide private R/W-Paved)
5. The Lot area tables should include S-1, AG-1 and OS-1.

Of Note:

This Preliminary plat review is subject to prior approval of BL-18-00007. Conditions and comments noted in this review are subject to change depending upon results of the Boundary Line adjustment.

Access:

1. **Timing of Improvements:** Per the Suncadia 2009 Development Agreement section 5.3 Infrastructure, Surety Bonding or Other Assurances. Infrastructure identified by Trendwest in an approved Site Development Plan must be provided and available for use before the issuance of the first certificate of occupancy for Master Planned Resort Accommodation Units included within such plan. For purposes of final plat approval or issuance of building permits, infrastructure may be guaranteed through surety bonding or other financial assurance device acceptable to the County. The estimated costs of providing all such guaranteed Infrastructure shall be reviewed and approved by the County Public Works Director or designee. Surety bonding or other acceptable financial device provided to the County shall be in an amount equal to at least 110% of such estimated costs as determined by Trendwest's architects and engineers.

Page 1 of 2

411 N. Ruby St. Suite 1
Ellensburg, WA 98926

TEL (509) 962-7523
FAX (509) 962-7663

Exhibit F-1 Suncadia MPR Conditions of Approval:

A-2 (a) Required Infrastructure and Utilities, as defined in the Development Agreement, shall be installed and completed or bonded or other financial guaranties or accommodations made for their completion prior to final plat approval of each sub phase.

2. Addressing: Contact the Kittitas County Rural Addressing Coordinator at (509) 962-7523 to obtain addresses prior to obtaining a building permit. A parcel cannot receive a building permit or utilities until such parcel is identified with a 911 address.
3. Civil Plans: Civil plans will be reviewed and approved as submitted prior to final platt approval in accordance with development agreement.