



# Kittitas County Community Development Services

Darryl Piercy, Director

7

Date: April 19, 2005  
To: Kittitas County CDS  
Jan Sharar, Staff Planner  
From: Derald Gaidos, Fire Marshal  
RE: P-04-08 Mellergaard

RECEIVED

APR 21 2005

KITTITAS COUNTY  
CDS

After reviewing the information I have the following requirements:

- Roads shall meet or exceeded Kittitas County Road Standards for emergency vehicle access.
- Fire Flow will be required for this development due to the density of lots. This can be accomplished with fire hydrants system, drafting ponds and or water tanks. 1000 GPM for 45 minutes of total storage capacity designated for fire fighting.

If any questions arise, please call.

Derald Gaidos

??Typo?? 7.31.13 note date