



June 20, 2008

Mackenzie Moynihan
Community Development Services


Dear Mackenzie:

Thank you for the opportunity to comment on the Gerard Preliminary Plat, #LP-08-00012. I recommend that this plat utilize a Group B water system to serve the 8 lots. A well site inspection must be performed to approve the site where the well is. The group B workbook and all associated paperwork must be turned in and the system design approved prior to final plat approval.

Soil logs are required for each lot where installation of a septic system is intended.

I look forward to assisting you if you have further questions or concerns.

Sincerely,


Holly Myers
Environmental Health Director
Kittitas County Public Health
(509)962-7584

