



KITITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: Dan Valoff
FROM: Christina Wollman, Planner II
DATE: February 5, 2008
SUBJECT: Tumbling Ridge PUD Rezone Z-07-16 and Preliminary Plat P-07-61

In order to fully review the environmental impacts of the Tumbling Ridge PUD, the Department of Public Works requests the following information:

Geotechnical Investigation: Geotechnical conditions shall be investigated and tested to verify geologic hazards.

Testing shall be completed by a civil engineer licensed to practice in the State of Washington in accordance with WSDOT Geotechnical Design Manual or AASHTO design manuals. Test results and the engineering report shall be provided to Public Works along with the road plans and profiles.