



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: September 30, 2021
SUBJECT: SX-21-00016 Hart

Public Works has reviewed the Shoreline Exemption Application. Please see comments below:

The building site is located within the 100-year floodplain and will need to comply with KCC Chapter 14.08 (Flood Damage Prevention). Depending on site-specific elevation data, this location may be eligible for removal by FEMA from the special flood hazard area. Please contact the Kittitas County Floodplain Manager at 509-962-7523 for additional information.