



# **KITITAS COUNTY**

## **DEPARTMENT OF PUBLIC WORKS**

---

### **MEMORANDUM**

---

TO: All Staff  
FROM: Public Works Plan Review Team  
DATE: November 1, 2022  
SUBJECT: SX-22-00018 Lauckhart

The Public Works Department has reviewed the Request for Shoreline Exemption.

#### **FLOOD:**

The proposed project is within the FEMA-identified special flood hazard area. Unless FEMA issues a letter of map amendment removing the structure from the special flood hazard area, a floodplain development permit is required, and the project will need to meet the standards identified in KCC 14.08..