



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: All Staff
FROM: Public Works Plan Review Team
DATE: February 1, 2023
SUBJECT: SX-23-00001 Roosevelt

ENGINEERING	No comments
FLOOD	The activity proposed on this property is within the 500-year floodplain. This area is identified as an area of moderate flood hazard risk. A floodplain development permit is only required for development within the 100-year floodplain or floodway. The applicant may want to consider voluntarily elevating their home. The applicant can contact Public Works staff for additional information.