

## **KITTITAS COUNTY**


### **DEPARTMENT OF PUBLIC WORKS**

---

**TO:** Ms. Chelsea Benner, Planner I

**COPY:** Ms. Candie Leader, Administrative Assistant  
Ms. Karen Hodges, Floodplain Manager

**DATE:** November 20, 2019

**FROM:** Mark R. Cook, Director 

**RE:** Thayer SEPA, SV 19-00001

---

Public Works has reviewed the submitted materials for Thayer SEPA, SV 19-00001. Our comments appear below for your use.

1. Applicant shall obtain a private bridge application from Public Works. Once received, Public Works will review engineering and provide final inspection of the proposed new private bridge.
2. A portion of the access driveway appears to be a candidate for widening within the delineated floodplain. Any fill in the floodplain will require a floodplain development permit. County code requires mitigation for floodplain fill.
3. The proposed parking area at the end of the driveway appears adequate meeting our required fire/life/safety turnaround.