



To Protect and Promote the Health and the Environment of the People of Kittitas County

September 10, 2018

Leslie Harmon
1540 Hidden Valley Rd.
Cle Elum, WA. 98922

RE: Approval of Harmon Group B Water System,
4 connection public water system located off of Hidden Valley Rd.
ID# Pending Kittitas County

Dear Steve,

The Group B Water System Application and Information Package for the above referenced project received in this office has been reviewed, and in accordance with the provisions of WAC 246-291, is hereby **FULLY APPROVED** by the Kittitas County Health Department.

Approval of this water system has been conditioned upon the agreement that management or ownership of the water system is being provided by a Satellite Management Agency.

Our approval of your Group B public water system design under Chapter 246-291 WAC does not confer or guarantee any right to withdraw or divert ground water. Contact our local planning department or the Washington State Department of Ecology for more information about your legal rights to use groundwater. Our approved number of service connections is based on your representation of available water quantity and may be reduced commensurate with your actual legal right to withdraw groundwater.

A Water Facilities Inventory form has been completed, and we have requested that the Washington State Department of Health assign this system an identification number. This



507 N. Nanum Street, St. 102 · Ellensburg, WA 98926
T: 509.962.7515 · F: 509.962.7581
www.co.kittitas.wa.us/health/



To Protect and Promote the Health and the Environment of the People of Kittitas County

number must be used on all future water samples to ensure proper credit toward your sampling requirements. At least one coliform drinking water sample every twelve months and one nitrate sample every thirty-six months is required to be submitted to a certified laboratory.

Sincerely,

A handwritten signature in black ink that reads "Holly Erdman". The signature is fluid and cursive, with the first letters of the first and last names being capitalized and prominent.

Holly Erdman
Environmental Health Specialist

Cc: Washington State Department of Health
file



507 N. Nanum Street, St. 102 · Ellensburg, WA 98926
T: 509.962.7515 · F: 509.962.7581
www.co.kittitas.wa.us/health/