



P.O. Box 777
 Leavenworth, WA 98826
 (509) 548-5361
 Fax (509) 548-1100

Pump Test Data Sheet

OWNER LESLIE L. HARMON DATE 8-17-04 PAGE 1 OF 2
 ADDRESS 1540 BRIDEN VALLEY RD. WELL LOCATION NW 1/4 SW 1/4 S32 T20 R9 17
CLE SUM. WA 98822
 PROPOSED USE DOMESTIC OPERATOR STEPHEN HOWARD
 ARRIVAL TIME 10:30 AM PM DEPARTURE TIME 3:55 AM PM
 MEASURING POINT IS TOP OF CASING WHICH IS 1.5 FT ABOVE BELOW SURFACE
 STATIC WATER LEVEL IS 46 FEET BELOW LAND AT 11:40 AM PM
 DEPTH OF WELL 92.5 FEET CASING INSTALLED +1.5" x 1.89"
 DIAMETER OF WELL 6 INCHES
 DISCHARGE RATE OF PUMPED WELL 9.3 GPM WELL TAG ID# AKJ874

CLOCK TIME	ELAPSED TIME SINCE PUMPING STARTED/STOPPED MINUTES	DEPTH TO WATER, BELOW LAND SURFACE (FEET)	DRAWDOWN OR RECOVERY (FEET)	PUMPING RATE (GPM)	REMARKS
11:40	0	46	0	14.2	CLOUDY
11:42	2	56	10	14.2	
11:44	4	65	19	14.2	
11:46	6	71	25	14.2	
11:48	8	75	29	13.6	SAND - FINE
11:50	10	77	31	9.6	CLEARING
11:52	12	77	31	9.6	
11:54	14	77	31	9.6	
12:00	20	77	31	9.6	
12:10	30	77	31	9.6	
12:20	40	77	31	9.6	CLEAR
12:30	50	77	31	9.6	
12:45	65	77	31	9.6	
1:00	80	77	31	9.6	
1:30	110	77	31	9.6	
2:00	140	77	31	9.6	
2:30	170	77	31	9.6	
3:00	200	77	31	9.6	
3:30	230	77	31	9.6	
3:45	245	77	31	9.6	STOPPED PUMPING