



KITTITAS COUNTY FIRE MARSHAL'S OFFICE

411 N. Ruby St., Suite 2, Ellensburg, WA 98926
Fire Marshal (509) 962-7000 Deputy Fire Marshal (509) 962-7657



November 9, 2023

Fire Marshal comments
Case Number: SP-23-00010

Zach Torrance-Smith, Project Planner

This application was reviewed by Dan Young in the Fire Marshal's Office. Dan can be reached at (509) 962-7000 or e-mail at Dan.Young@co.Kittitas.wa.us. Where there are difficulties in meeting these conditions or if additional information is required, contact Dan in the Fire Marshal's office immediately.

Approved fire apparatus turnarounds are required for this project. The indicated provisions for turning around fire apparatus are not adequate. Provide a turnaround meeting the requirements of the International Fire Code Appendix D.

This application is sited in the designated high fire hazard Wildland - Urban Interface zone. Additional setback, building construction, access, fire flow and addressing requirements may be applied at the time of building permit application.

No gate may be installed across a required fire department access road or driveway without first obtaining a permit from the fire marshal's office. Inspection and testing of the gate will be required.

Dan Young
Fire Marshal

These comments are based on the information provided. Any revision to the proposal may change the Fire Marshal comments.