



KITTITAS VALLEY FIRE & RESCUE

400 E Mt View Ave • Ellensburg WA 98926 • (509) 933-7241 • Fax (509) 933-7245 • prevention@kvfr.org

KVFR Prevention Short Plat Comments

Project: Carr
Permit#: SP-24-00002
Date: 03/21/2024

I have reviewed the Short Pat and associated documents for the listed project and/or construction for Kittitas County Fire District 2 (KVFR). The Fire District has no code enforcement authority, so my input is from a fire department response and operational basis.

Comments:

- Fire apparatus access roads exceeding 150' shall be provided with a temporary or permanent turnaround meeting the requirement 2021 IFC Appendix D.
- Fire apparatus access roads shall not exceed 10% in grade. This is especially critical in our valley's climate.
- The IFC Appendix D requires the road be a minimum of 20' wide and capable of supporting an imposed load of at least 75,000 lbs.
- Our standard turning radius is a minimum of 23' inside and 45' outside.

Thank you,

A handwritten signature in black ink, appearing to read "Dan Johnson".

Dan Johnson
Fire Prevention Captain
Fire Investigator, IAAI FIT
Kittitas Valley Fire & Rescue
400 E. Mountain View Ave, Ellensburg WA 98926
Office: 509.933.7241
Cell/Text: 509.856.4455
Fax: 509.933.7245
prevention@kvfr.org

