

(1) OWNER: Name: DON NEY

Address: Game Farm Rd

(2) LOCATION OF WELL: County: RITCHEY

Section: SW 1/4 Township: 29 N Range: 19 W

Bearing and distance from section or subdivision corner:

(3) PROPOSED USE: Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

(4) TYPE OF WORK: Owner's number of well (if more than one):  
New well  Method: Dug  Bored   
Deepened  Cable  Driven   
Reconditioned  Rotary  Jetted

MATERIAL	FROM	TO
TOP SOIL	0	3
Sandy loam	3	90
fine sand (some water)	90	95
Sandy clay	95	140
coarse gravel (water)	140	160

(5) DIMENSIONS: Diameter of well 6 1/2 inches  
Drilled 160 ft. Depth of completed well 160 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 1/2" diam. from 0 ft. to 160 ft.  
Threaded  Diam. from     ft. to     ft.  
Welded  Diam. from     ft. to     ft.

Perforations: Yes  No   
Type of perforator used:  
SIZE of perforations in by in  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

Screens: Yes  No   
Manufacturer's Name:  
Type: Model No:  
Diam. Slot size from ft. to ft.  
Diam. Slot size from ft. to ft.

Gravel packed: Yes  No  Size of gravel:  
Gravel placed from ft. to ft.

Surface seal: Yes  No  To what depth? 70 ft.  
Material used in seal: REINFORCED CONCRETE  
Did any strata contain unusable water? Yes  No   
Type of water? Depth of strata:  
Method of sealing strata off:

(7) PUMP: Manufacturer's Name:  
Type: H.P.:

(8) WATER LEVELS: Land-surface elevation above mean sea level:  
Static level 50 ft. below top of well Date 6-2-84  
Artesian pressure lbs. per square inch Date:  
Artesian water is controlled by (Cap, Valve, etc.):

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.  
Was a pump test made? Yes  No  If yes, by whom?  
Yield: gal/min with ft. drawdown after hrs.

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test:  
Meter test: 20 gal/min with 100 ft. drawdown after 1 hrs.  
Artesian flow: g.p.m. Date:  
Temperature of water: Was a chemical analysis made? Yes  No

Work started 6-1-84, 1984 Completed 6-2-84, 1984

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME: BACH DRILLING CO.  
(Person, firm, or corporation) (Type or print)

Address: ELLENSBURG, WA SH.

[Signed]: \_\_\_\_\_  
(Well Driller)

License No. 22 Date: 6-2-84, 1984