



KITTITAS COUNTY DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: Community Development Services
FROM: Kelly Bacon, Engineer Technician I *KB*
DATE: December 16, 2015
SUBJECT: Poulsen Short Plat SP-15-00005

The following shall be conditions of preliminary approval:

1. Only one approach per parcel of land will be granted per the Kittitas County Road Standards.
2. Joint-Use Driveway: A joint-use access shall serve no more than two tax parcels. See Kittitas County Road Standards, 9/6/05 edition.
 - a. Access easements shall be a minimum of 20' wide. The roadway width shall have a minimum width of 12'.
 - b. The surface requirement is for a minimum gravel surface depth of 6".
 - c. Maintenance of driveway approaches shall be the responsibility of the owner whose property they serve. The County will not maintain accesses.
 - d. Any further subdivision or lots to be served by proposed access may result in further access requirements.

Single-Use Driveway: A single-use access shall serve no more than one lot. See Kittitas County Road Standards, 9/6/05 edition.

- a. The roadway shall be a minimum of 8' wide with gravel surface.
 - b. Maintenance of driveway approaches shall be the responsibility of the owner whose property they serve. The County will not maintain accesses.
 - c. Any further subdivision or lots to be served by proposed access may result in further access requirements.
3. Plat Notes: Plat notes shall reflect the following:
 - a. Maintenance of the access is the responsibility of the property owners who benefit from its use.

- b. An approved access permit will be required from the Department of Public Works prior to creating any new driveway access or performing work within the county road right of way.
 - c. Any further subdivision or lots to be served by proposed access may result in further access requirements. See Kittitas County Road Standards.
 - d. A public utility easement 10 feet in width is reserved along all lot lines. The 10 foot easement shall abut the exterior plat boundary and shall be divided 5 feet on each side of interior lot lines. Said easement shall also be used for irrigation
4. Plat Approvals: All plats must show the acceptance signature of the County Engineer. The acceptance block shall be as follows (per KCC 16.24.170):

EXAMINED AND APPROVED
This ____ day of _____, A.D., 20____.

Kittitas County Engineer

5. Access Permit: An approved access permit shall be required from the Department of Public Works prior to creating any new driveway access or performing work within the county road right of way.
6. Addressing: Contact the Kittitas County Rural Addressing Coordinator at (509) 962-7523 to obtain addresses prior to obtaining a building permit. A parcel cannot receive a building permit or utilities until such parcel is identified with a 911 address.
7. Mailbox Placement: Mailboxes must be approved by U.S. Postal Service. Mailbox locations are site specific. Contact your local Post Office for location and design standards before beginning construction.