



KITITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: Community Development Services
FROM: Public Works Planning Review Team
DATE: May 18, 2021
SUBJECT: SE-21-00009 Hobbs

SEPA Application Comments

- Any grading over 100 cubic yards of material requires a grading permit. Any grading over 500 cubic yards of material will require engineered grading and storm water plans. See Kittitas County Code chapter 14.05.
- An access/address permit has been issued.
- Per KCC 14.05.110: Excavations shall not constrict or alter the existing flow of storm water, streams, or other historical flow.

Please contact Kittitas County Public Works (509) 962-7523 with any questions.