



KITTITAS COUNTY

DEPARTMENT OF PUBLIC WORKS

MEMORANDUM

TO: Community Development Services
FROM: Public Works Plan Review Team
DATE: November 23, 2021
SUBJECT: SE-21-00024 Shree Thorp

SEPA Application Comments

- Any Grading over 100 cubic yards of material would require a grading permit. Grading over 500 cubic yards of material will require engineered grading and storm water plans. See Kittitas County Code chapter 14.05.
- Please provide stormwater plans for review if any changes are made to the existing system. The stormwater system will comply with the Stormwater Management Manual for Eastern Washington (SWMMEW).
- A right-of-way permit would be required from Public Works if any work is performed within the county right-of-way.

Please contact Kittitas County Public Works (509) 962-7523 with any questions.