



# Memo

**To:** Lindsey Ozbolt, CDS

**From:** Holly Myers, Environmental Health Supervisor


**Date:** September 1, 2015

**RE:** VA-15-00001 Heric

---

After review of this Zoning Variance land use application, it appears that the proposed structure will not impact the existing water source or septic system. The new garage structure must meet setback of 10 feet from septic drain field as per Kittitas County Code Chapter 13.04.080.

Holly Myers, Environmental Health Supervisor



507 N. Nanum Street, St. 102 · Ellensburg, WA 98926

T: 509.962.7515 · F: 509.962.7581

[www.co.kittitas.wa.us/health/](http://www.co.kittitas.wa.us/health/)