



# KITTITAS COUNTY FIRE MARSHAL'S OFFICE

411 N. Ruby St., Suite 2, Ellensburg, WA 98926

Office (509) 962-7657 Fax (509) 962-7682

September 29, 2016

Dusty Pilkington  
Community Development Services  
411 N. Ruby Street, Suite 2  
Ellensburg, WA 98926

Re: Mostofi (VA-16-00001)

Dear Mr. Pilkington:

After conducting a review of the above named project, I have the following comments:

- Any new driveway must comply with Kittitas County Code, i.e. driveway lengths over 150' are have a width of no less than 16 feet.
- All new construction must meet the Wildland Urban Interface (WUI) Code for building components and defensible space.

Any questions or concerns regarding fire service features may be directed to the Kittitas County Fire Marshal's Office at 509-962-7000.

Sincerely,

Josh Hink  
Fire Marshal