

## Kittitas County Fire Marshal's Office 411 N. Ruby St. Suite 2 Ellensburg, WA 98926 509-962-7657 Fax 509-962-7682

## FIRE LIFE SAFETY INSPECTION REPORT

Building/Business Owner Name:	C	ANYON RIVER RANCH	Insp	pection Date: 01/25/2016	
Business Name: Canyon River	L R	anch/REOS Fly Address: 14,7	700	SR 821 Ellewsburg W	A
Inspection Issued To: Keuw	m	Anch/Reos Fly Address: 14,7	P. 0	Box 706 Ellewsbung W	A
Type of Business: Lodge / F				: 509-933-2100	
		your property. During this inspection con			een
A. Exterior Assessment		E. Fire Alarm System		I. Kitchen Suppression	
1 - Building number not posted		1 - Alarm Service Report		1 - Cleaning of hood and duct	X
2 - Obstructed FDC		2 - Devices obstructed		2 - Illegal cooking operation	_
3 - Obstructed fire hydrant		3 - Alarm Maintenance		3 - Six month service needed	
4 - Gas meter protection		F. Flammable/Combustible Liquid	ids	J. Automatic Sprinkler	
5 - Storage proximity		1 - Storage cabinet		1 - Annual service needed	
6 - Storage under eaves		2 - Improper housekeeping		2 - FDC cap needed	
B. Exits		3 - No storage area		3 - Hanging material	434
1 - Exit travel		4 - Close to heating appliance		4 - Sprinkler clearance	
2 - Exits obstructed		5 - Fueled equipment	· ·	5 - Provide sprinkler protection	
3 - Panic hardware		6 - Oily rags		6 - Damaged/Painted heads	
4 - Number of exits		7 - Compressed gas tanks		7 - Spare heads and/or wrench	
5 - Unapproved locking devices		8 - Equipment rooms		K. Fuel Dispensing	
C. Exit Lighting and Signs		G. Electrical		1 - Fire extinguisher	
1 - Exit signs battery backup	X	1 - Extension cord usage		2 - Emergency shutoff	
2 - Exit signs required		2 - Electrical panel labeling		3 - Provide signage	
3 - Emergency lighting		3 - Portable heaters		4 - Replace hoses	
4 - Exit sign burnt out		4 - Improper power strip usage		L. Hotel/Apartments	
5 - "to remain unlocked" sign		5 - Panel obstructed		1 - Evacuation routes	
D. Extinguishers		6 - No cover plate		2 - Fire alarm system	
1 - Class K extinguisher		7 - Multi-plug adapter		3 - Smoke detectors	
2 - Number of extinguishers		1 0 1			
3 - Extinguisher placement		H. Fire Walls and Doors		X. No Apparent Violations	
4 - Extinguisher obstructed		1 - Restrained fire door	-	1 - No Apparent Violations	
5 - Extinguisher maintenance	<b>√</b>	2 - Breached wall or ceiling	_	1 110 12ppuront (10.mions	1
6 - Signs indicating location		3 - Fire assembly needs repair			
				6	
Notes: 21, 3527 B/R-2	V-	A , Fire Extinguister ane in Regulation Please replace	DUE	FOR ANNUAL SCHULE.	
Mood And Duct Cleaning	, ,	Keguineo. PIEASE REPlACE	BAtte	Exies in Exit Cighting	<u>·</u>
Remarks:					
icemarks.					
				Fire Inspection reports also	
your invoice. Please remit payment in the					
			amou	unt of \$ <u>640 </u> within 30 day	'S.
1					
Inspector: Josh Hink-DFM Received By: KEVIN Smith					
mspector: Josh Proper	יע				
SIGNATURE KEVIN L. SMITH DATE 1/25/16					
SIGNATURE A	_	PRINT NAME KEVIZ	n L.	MHL DATE 1175	116
DISTRIBUTION: WHITE - OCCUPANT CANARY - PREVENTION					