KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-11-00577	**OWNER'S NAME:**	PARKER
DATE:	1/6/2015	**TYPE:**	Stove or fireplace
TIME STARTED:	3:42 PM	**INSPECTOR:**	Amber Green
MAP NUMBER:	21-14-34053-0406		

	1. Existing Fireplace needs 24" clear to unprotected wall or 8" clear to non combustible (
	Protected) wall.

INSTRUCTIONS: Modify existing sidewalls to be in compliance with above. Call for reinspect.

NEXT INSPECTION:

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____amber.green **@co.kittitas.wa.us**